



August 2, 2016

RECTORSEAL
KATHLEEN KELCH
2601 SPENWICK DRIVE
HOUSTON TX 77055

Re: Description: TRAP SEAL DEVICE
Manufacturer: RECTORSEAL
Product Name: (trans id 2744649) FLOOR DRAIN TRAP SEAL
Model Number(s): SS2009V, SS3009V, SS3509V AND SS4009V
Product File No: 20160207

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.32 (3) (c) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2021.

This alternate approval is contingent upon compliance with the following stipulation(s):

- These devices are not trap seal primers and shall not be used as such.
- These devices are not backwater valves and shall not be used as such.
- These devices shall maintain conformance to ASSE 1072.
- These devices shall be installed in accordance with the manufacturer's published instructions.
- These devices shall not be installed in areas subjected to less than atmospheric pressure.
- Each device shall be marked with the following:

1. manufacturer's name or trademark; and
2. UPC certification mark.

Packaging shall be marked with the following:

- a. manufacturer's name or trademark;
- b. model number or description of device;
- c. rating for type of floor;
- d. rating for grease laden wastes (if applicable); and
- e. floor drain size.

RATED FLOWS

Model Number	Minimum Required Flow Rate (gpm)¹
SS2009V	12.0
SS3009V	34.0
SS3509V	52.0
SS4009V	73.0

1 = ASSE Standard 1072, section I

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail